

Zertifikat Certificate



Zertifikat Nr. *Certificate No.*
R 60092004

Blatt *Page*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i> (day/mo/yr)
	0001-- 27114219 001	13.02.2014	

Genehmigungsinhaber <i>License Holder</i>	Fertigungsstätte <i>Manufacturing Plant</i>
BEMİS ELEKTRİK SAN.TİC.LTD.ŞTİ. VATAN MAH. VOLKAN SOK.NO:13 YILDIRIM BURSA Türkiye	BEMİS ELEKTRİK SAN.TİC.LTD.ŞTİ. VATAN MAH. VOLKAN SOK.NO:13 YILDIRIM BURSA Türkiye

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
IEC 60670-1:2002
IEC 60670-24:2011

Zertifiziertes Produkt <i>(Geräteidentifikation)</i>	Lizenzentgelte - Einheit
<i>Certified Product (Product Identification)</i>	<i>License Fee - Unit</i>

Terminal Block (electrical) Terminal Box

Type Designation:	a.) BEM 70-850	5
	b.) BEM 73-900	1
	c.) BEM 75-100	1
Rated Voltage :	AC 400V	
Rated Current :	a.) 32 A; b.) 63A	
	c.) 120A	

7

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle

Sahure Oralalp
Zertifizierungsstelle